

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13674

1. OWNER Carson City Public Works ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 3300 Butte Way Bennett Ave  
Carson City, Nevada 89701 Carson City, Nevada  
 2. LOCATION 125' X NE 1/4 Sec 32/55 between T. 15 N/S R. 20 E Carson City County  
 PERMIT NO. 56531 Waiver 349 Parcel No. NA Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Hardpan		0	8	8
Clay/Sand/DG		8	25	17
Stringers Clay/ DG		25	130	105
Granite/Bedrock		130	248	118
Abandon #45 7 BAG mix 4 yds.				
Set 2" Tremmie Pipe		0	220	
Pumping Grout				
Pull 20'		220	200	
Pumping Grout				
Pull 20'		200	180	
Pumping Grout				
Pull 20'		180	160	
Pumping Grout				
Pull 20'		160	120	
Pumping Grout				
Pull 20'		120	100	
Pumping Grout				
Pull 20'		100	80	
Pumping Grout				
Pull 20'		80	60	
Pumping Grout				
Pull 20'		60	40	
Pumping Grout				
Pull 20' and top off well				

Abandoning was done in accordance to the rules and regulations of the State of Nevada. Engineer observed this job.

Date started 9/23, 1991  
 Date completed 9/24, 1991

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
NA		

8. WELL CONSTRUCTION

Depth Drilled 248 Feet Depth Cased \_\_\_\_\_ Feet

HOLE DIAMETER (BIT SIZE)

From		To	
<u>8 1/4"</u> Inches	0	Feet	<u>248</u> Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet
_____ Inches	_____ Feet	_____ Feet	_____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
		NA		

Perforations:  
 Type perforation \_\_\_\_\_  
 Size perforation NA  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
248  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
7 BAG mix

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL

Static water level DRY feet below land surface  
 Artesian flow NA G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Humboldt Drilling And Pump Co.. Contractor  
 Address P.O. BOX 590  
Winnemucca, Nevada Contractor 89446-0590  
 Nevada contractor's license number issued by the State Contractor's Board 015234  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533  
 Signed C. P. Epler  
 By driller performing actual drilling on site or contractor  
 Date 10-9-91