WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36084
Permit No.
Basin 6-87

NOTICE OF INTENT NO. 20128

1. OWNER Dr. LEX SIMPSON
MAILING ADDRESS 2600 Kinney Lane
Reno, NV 89511

ADDRESS AT WELL LOCATION Same

2. LOCATION SE ¼ NE ¼ Sec. 2 T. 18N N/S R. 19 E. Washoe County
PERMIT NO. (Issued by Water Resources) 41-353-04 (Parcel No.) SW Reno area (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☒ Recondition
☐ Deepen ☐ Abandon ☐ Other Clean

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
RECONDITIONING WELL				

Install tremie line to existing bottom of well. Pump neat cement back to 86 ft. (to block off sand producing stratas) Cure 24 hrs. Checked hole. Discovered perforations not on log. Install tremie line to 86 feet. Pump neat cement to 12 feet. Cure 24 hrs. Drill through cement out the bottom. Hole becomes unstable & making water at 162 ft. Develop with air. Well making 16½ GPM of clear water.

'91 OCT 22 A1:19
STATE ENGINEER

Date started 9-30-91, 19
Date completed 10-3-91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 162 Feet Depth Cased 160 original Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
	None installed			

Perforations:
Type perforation
Size perforation
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☐ No
From feet to feet

9. WATER LEVEL
Static water level 0 feet below land surface
Artesian flow 16½ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date October 18, 1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627