ARY—CLIENT'S COPY
NK—WELL DRILLER'S COPY

$1520

PRINT OR TYPE ONLY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36109
Permit No.
Basin

NOTICE OF INTENT NO. 1520

1. OWNER Lahontan Farms
MAILING ADDRESS 4771 Conte
Carson City Nev

ADDRESS AT WELL LOCATION Behind Lahontan Diversion Dam

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 19 N/S R. 27 E. Churchill County
PERMIT NO. 42274796 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☑ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	150	150
Gravel	✓	150	300	150
Sandy Clay	✓	300	355	55
Sand	✓	355	356	1
Clay	✓	356	360	6
Sand		360	361	1
Clay	✓	361	370	9
Sand	✓	370	375	5

Date started 4/12, 19 84
Date completed 5/2, 19 84

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	1000	0	540

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole 22" inches Total depth 375 feet
Casing record 16"
Weight per foot ____ Thickness 250

Diameter	From	To
16" inches	0 feet	375 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 375 feet 18 yds

Perforations:
Type perforation Factory
Size perforation ¼ x 3
From 120 feet to 240 feet 3-1/2 Slot
From 240 feet to 375 feet Outlet Slot
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 90 feet below land surface
Flow 0 G.P.M. 1000 P.S.I.
Water temperature Cold °F. Quality

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Sierra Pump + Drilling (Contractor)
Address Carson City Nev (Contractor)
Nevada contractor's license number 0122360
Nevada contractor's drillers number 849 3721
Nevada driller's license number 1001
Signed Cirtus Bladsworth by A R Strauss (Actual Driller / Contractor)
Date 5/13/84

USE ADDITIONAL SHEETS IF NECESSARY

CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

Log No. 36109
Permit No.
Basin

#1520

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1520

OWNER Lahontan Farms
MAILING ADDRESS 4771 Conte
Carson City Nev.

ADDRESS AT WELL LOCATION Behind Lahontan Diversion Dam

2. LOCATION NE ¼ NE ¼ Sec. 31 T. 19 N/S R. 27 E. Churchill County

PERMIT NO. 4474274796 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☑ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☑ Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	150	150
Gravel	✓	150	300	150
Sandy Clay	✓	300	355	55
Sand	✓	355	356	1
Clay	✓	356	360	6
Sand		360	361	1
Clay	✓	361	370	9
Sand	✓	370	375	5

Date started 4/12, 1984
Date completed 5/2, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Blown	1000	0	5 Hr.

BAILER TEST

G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION

Diameter hole 22" inches Total depth 375 feet
Casing record 16"
Weight per foot ____ Thickness 250

Diameter	From	To
16" inches	0 feet	375 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐ 18 yrs
Gravel packed from 50 feet to 375 feet

Perforations:
Type perforation Factory
Size perforation ⅛ x 3
From 120 feet to 240 Single Slot feet
From 240 feet to 375 Double Slot feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL

Static water level 90 feet below land surface
Flow 0 G.P.M. 1000 P.S.I.
Water temperature Cold °F. Quality

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Sierra Pump + Drilling (Contractor)
Address Carson City Nev. (Contractor)
Nevada contractor's license number 0122360
Nevada contractor's drillers number —
Nevada driller's license number 1001 (Actual Driller)
Signed Cirtus Bladsworth by [signature] (Contractor)
Date 5/13/84

(Rev. 6-81) USE ADDITIONAL SHEETS IF NECESSARY O-627