WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36 H1
Permit No.
Basin 6-85

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14197

1. OWNER Howard Hughes Properties
MAILING ADDRESS 6530 S. Paradise Rd Las Vegas NV 89119
ADDRESS AT WELL LOCATION 3000 Pyramid Lake Rd. Sparks NV

2. LOCATION SW ¼ SE ¼ Sec. 3 T. 20 N/S R. 20 E. Washoe County
PERMIT NO. M/O-290 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. TYPE OF WORK Abandonment
New Well ☐ Recondition ☐
Deepen ☐ Other ☒

4. PROPOSED USE Abandonment
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ Hugen

6. LITHOLOGIC LOG MW #6

Material	Water Strata	From	To	Thickness
Abandonment pressure grout (neat cement)		0	35'	

'92 FEB 26 A11:41
RECEIVED
STATE ENGINEERS

Date started 9/4, 1991
Date completed 9/4, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

11:00 AM 17 OCT 91

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter ..... inches Total depth ..... feet
..... inches
..... inches
Casing record N/A
Weight per foot ..... Thickness .....

Diameter	From	To
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes ☐ No ☐ Type .....
Depth of seal N/A ..... feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation .....
Size perforation .....
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 26.64 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Herbert Andresen
Contractor
Address 1635 Belford RD. RENO NEV
Contractor
Nevada contractor's license number issued by the State Contractor's Board .....
Nevada contractor's driller's number issued by the Division of Water Resources .....
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1023
Signed Herbert Andresen
By driller performing actual drilling on site or contractor
Date 9/25/91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No.
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6110

1. OWNER HOWARD HUGHES PROPERTIES
MAILING ADDRESS 6530 S. PARADISE ROAD
LAS VEGAS, NEVADA 89119

ADDRESS AT WELL LOCATION 8000 PYRAMID LAKE ROAD, SPARKS, NEVADA

2. LOCATION SW ¼ SE ¼ Sec. 3 T 20 N/S R. 20 E WASHOE County
PERMIT NO. M/O-290 Issued by Water Resources | Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☒
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☐
Other ☒ Auger

6. LITHOLOGIC LOG MW#6

Material	Water Strata	From	To	Thickness
GRAVELLY SAND		0'	10'	10'
SILTY SAND		10'	13'	3'
GRAVELLY SAND		13'	19'	6'
SANDY GRAVEL		19'	25'	6'
GRAVELLY SAND	X	25'	35'	10'

'92 FEB 26 AM 11:41 STATE ENGINEER RECEIVED

Date started SEPTEMBER 20, 19 90
Date completed SEPTEMBER 20, 19 90

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	N/A		

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. N/A Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 4 inches Total depth 35 feet
inches
inches
Casing record PVC Sch 40
Weight per foot N/A Thickness N/A

Diameter	From	To
4 inches	0 feet	35 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type NEAT CEMENT
Depth of seal 22 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 22 feet to 35 feet

Perforations:
Type perforation MACHINE SLOTTED
Size perforation 0.020 INCH
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 26.04 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature COLD °F Quality CLEAR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HARLAN D. ANDRESEN
Contractor
Address 1635 BELFORD RD., RENO, NEVADA 89506
Contractor
Nevada contractor's license number issued by the State Contractor's Board
Nevada contractor's driller's number issued by the Division of Water Resources
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature]
By driller performing actual drilling on site or contractor
Date 10/22/90

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627