Copy? IS THERE 4 OR 5 WELLS ?

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36124
Permit No.
Basin

NOTICE OF INTENT NO.

1. OWNER CHEVRON USA
MAILING ADDRESS P. O. BOX 220
SEATTLE, WA 98111

ADDRESS AT WELL LOCATION US HIGHWAY 40
AND TENTH STREET
CARLIN, NV

2. LOCATION SE ¼ NE ¼ Sec. 27 T. 33 N/S R. 52 E. ELKO County
PERMIT NO. M/O-297A
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill, Cobbles		0	25	25'
Silt, ~~Sand~~ Clay		26	32	6'
~~Clay~~, Silt sand	Very	32	44	12'

PA by log # 37170

Date started 9-10, 1990
Date completed 9-21, 1990

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

8. WELL CONSTRUCTION
Depth Drilled 44 Feet Depth Cased 3 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	44 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½"	PVC	Sch. 40	0	34

Perforations:
Type perforation Machine slotted
Size perforation .020
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 34'
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 34 feet to 44 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow N/A G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name P C Exploration
Address P. O. Box 96 (Contractor)
Woods Cross, UT 84087 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0028767
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1605
Signed Ray Fraser (By driller performing actual drilling on site or contractor)
Date 9-28-90

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36124
Permit No.
Basin

NOTICE OF INTENT NO.

1. OWNER Chevron USA
MAILING ADDRESS P. O. BOX 220
SEATTLE, WA 98111

ADDRESS AT WELL LOCATION US HIGHWAY 40
AND TENTH STREET
CARLIN, NV

2. LOCATION SE ¼ NE ¼ Sec. 27 T. 33 N/S R. 52 E. ELKO County

PERMIT NO. M/O-297A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
FILL, COBBLES		0	25	25'
SAND, CLAY		26	32	6'
SAND, SILT	34	32	44	12'

P&A by Log # 38207

Date started 9-10-, 19 90
Date completed 9-21, 19 90

7. WELL TEST DATA
TEST METHOD: ☒ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A			

8. WELL CONSTRUCTION
Depth Drilled 44 Feet Depth Cased 3 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11 Inches		0 Feet	44 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4½"	PVC	Sch. 40	0	34'

Perforations:
Type perforation Machine Slotted
Size perforation .020
From feet to feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 34'
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 34 feet to 44 feet

9. WATER LEVEL
Static water level 38 feet below land surface
Artesian flow n/a G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name PC EXPLORATION (Contractor)
Address P. O. BOX 96 (Contractor)
WOODS CROSS, UT 84087
Nevada contractor's license number issued by the State Contractor's Board 0028767
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1605
Signed Ray Fraser (By driller performing actual drilling on site or contractor)
Date 9-28-90

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627