

OFFICE USE ONLY
Log No. 36168
Permit No. _____
Basin _____

I

WELL DRILLER'S REPORT

PRINT OR TYPE ONLY

Please complete this form in its entirety

NOTICE OF INTENT NO. 16414
ADDRESS AT WELL LOCATION 1079 LOG LABIN
Gardnerville, NV.

1. OWNER Griswold Construction
MAILING ADDRESS Po Box 1622
Gardnerville, NV 89410

2. LOCATION SE 1/4 SE 1/4 Sec. 12 T. 12 N/S R. 20 E Douglas County
PERMIT NO. 23-232-20 Parcel No. _____ Subdivision Name Sage Wood Estates

Issued by Water Resources

<p>3. TYPE OF WORK</p> <p>New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/> Deepen <input type="checkbox"/> Other <input type="checkbox"/></p>	<p>4. PROPOSED USE</p> <p>Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/> Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/> Other <input type="checkbox"/></p>	<p>5. TYPE WELL</p> <p>Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/> Other <input type="checkbox"/></p>
--	---	---

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
CLAY		0	15	15
gravel & Rocks		15	30	15
CLAY & ROCKS		30	100	70
CLAY		100	110	10
CLAY & ROCKS		110	215	105
CLAY		215	225	10
gravel & Rocks		225	270	45
CLAY		270	275	5
gravel & Rocks		275	290	15
CLAY		290	295	5
gravel & Rocks		295	300	5

APR 10 AM 12:29

STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION

Diameter 10 inches Total depth 300 feet

Casing record _____
Weight per foot _____ Thickness 1.88

Diameter	From	To
<u>6</u> inches	<u>+ 1</u> feet	<u>300</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
Depth of seal 50 feet
Gravel packed: Yes No
Gravel packed from 50 feet to 300 feet

Perforations:
Type perforation FACTORY Slot
Size perforation 3/32" x 3/32"
From 260 feet to 300 feet

9. WATER LEVEL

Static water level 190 feet below land surface
Flow 0 G.P.M. 10 PSI
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Energy Exploration Drilling Contractor
Address Po Box 1538 Minden NV 89423 Contractor

Nevada contractor's license number issued by the State Contractor's Board 21491
Nevada contractor's driller's number issued by the Division of Water Resources 1407
Nevada driller's license number issued by the Division of Water Resources, the onsite driller 1407
Signed Jim Woods By driller performing actual drilling on site or contractor
Date 4-7-91

Date started 4-3 1991
Date completed 4-5 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. Draw down _____ feet _____ hours
G.P.M. Draw down _____ feet _____ hours
G.P.M. Draw down _____ feet _____ hours