

OFFICE USE ONLY  
 Log No. 36171  
 Permit No. 56251  
 Basin. 9-108

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 16380

1. OWNER GENE MENESINI ADDRESS AT WELL LOCATION: 1/4 MILE FROM MCKENZI AVE  
 MAILING ADDRESS PO BOX 208  
YERINGTON NEVADA 89447

2. LOCATION NE 1/4 NE 1/4 Sec 11 T 12 N/S R 25 E LYON County  
 PERMIT NO. 56250T + 56251 N/A Parcel No. N/A Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL ALFALFA		0	10	10
SAND		10	15	5
SAND LT GRAVEL LT CLAY		15	325	310
SAND LG GRAVEL GRAY CLAY		325	345	20
LG & SM SAND & GRAVEL		345	363	18
GRAY CLAY SILT		363	370	7
LG & SM SAND & GRAVEL		370	405	35
LG & SM SAND & GRAVEL THIN LAYERS OF GRAY CLAY		405	417	12

8. WELL CONSTRUCTION  
 Diameter 28 inches Total depth 417 feet  
 Casing record 16"  
 Weight per foot 42.05# Thickness .250

Diameter	From	To
<u>16</u> inches	<u>+2</u> feet	<u>64.51</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type CEMENT GROUT  
 Depth of seal 53 feet  
 Gravel packed: Yes  No   
 Gravel packed from 53 feet to 417 feet

Perforations:  
 Type perforation MILL SLOT & SHUTTER SCREEN  
 Size perforation .80 (Mill), .100 (Shutter)  
 From 64.5 feet to 317. feet  
 From 317. feet to 417. feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 04-26 1991  
 Date completed 04-30 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 39.9" feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name SARGENT IRRIGATION COMPANY  
9955 NORTH VIRGINIA STREET  
 Address RENO NV 89506 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 21246  
 Nevada contractor's driller's number issued by the Division of Water Resources 1391  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1541  
 Signed [Signature] by driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_