WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36172
Permit No.
Basin

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17234

1. OWNER Gary Mortimer
MAILING ADDRESS 732 Indian Trail RD
Gard. NV 89410

ADDRESS AT WELL LOCATION 1548 Chance
Gard. NV

2. LOCATION NE ¼ SE ¼ Sec. 27 T. 13 N/S R. 20 E. Douglas County
PERMIT NO. (Issued by Water Resources) 23-260-24 (Parcel No.) N/A Orchard + Tolar Area (Subdivision Name)

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
[illegible]		0	10	10
[illegible]		10	25	15
Brown Clay		25	40	15
[illegible]		40	95	55
Clay Seams				
Clay		95	115	20
[illegible]	X	115	125	10
[illegible]	X	125	140	10

'91 MAY 20 A9:39
STATE ENGINEERS OFFICE

Date started 4 - 22, 1991
Date completed 4 - 4-25, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
[illegible]	[illegible]	[illegible]	[illegible]
[illegible]	[illegible]	[illegible]	[illegible]
[illegible]			

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10" inches Total depth 140 feet
• ..... inches
..... inches
Casing record 6 5/8 steel
Weight per foot ..... Thickness 1.53

Diameter	From	To
..... inches	+2 feet	120 feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet
..... inches	..... feet	..... feet

Surface seal: Yes ☑ No ☐ Type Cement Grout
Depth of seal 100' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 140 feet to 100 feet

Perforations:
Type perforation 3/2 x 3/32
Size perforation Mill Sheet
From 120 feet to 140 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 60' feet below land surface
Flow ..... G.P.M. 35 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Lawchock Drilling Inc. (Contractor)
Address Rt #3 2668 Fuller, Minden NV 89423 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 021268
Nevada contractor's driller's number issued by the Division of Water Resources 1380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674
Signed [illegible]
By driller performing actual drilling on site or contractor
Date [illegible]

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627