

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 17231

PRINT OR TYPE ONLY

1. OWNER DON CHAMBERS ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS P.O. Box 2810 Not assigned as yet, corner of Choke-  
Gardnerville, NV 89410 cherry & Borda Gardnerville, NV 89410  
 2. LOCATION NE 1/4 SE 1/4 Sec. 35 T. 13 N/S R. 20 E Douglas County  
 PERMIT NO. 23-470-06 Wildflower  
 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	4	4
Gravel and sand mix		4	78	74
Clay seam with sand		78	90	12
Gravel, firm and hard		90	98	8
Brown clay, tight		98	163	65
Clay and gravel mix		163	178	15
Clean gravel carrying water	xxx	178	200	22
TD at 200 ft				

8. WELL CONSTRUCTION  
 Diameter \_\_\_\_\_ inches Total depth 200 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record Steel 6 5/8"  
 Weight per foot 13.03 Thickness .188  

Diameter	From	To
<u>6 5/8</u> inches	<u>2</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Concrete  
 Depth of seal 70 feet  
 Gravel packed: Yes  No   
 Gravel packed from 70 feet to 200 feet  
 Perforations:  
 Type perforation Factory Mill Slot  
 Size perforation 3" x 3 1/2"  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started April 16, 1991  
 Date completed April 19, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>Flushed well with clean water to remove drill mud and to gravel pack annulus.</u>			
<u>Developed well with 250 - 450 air to clean and blowing 25 gpm from 175 ft.</u>			

BAILER TEST

G.P.M.	Draw down	feet	hours
_____	_____	_____	_____
_____	_____	_____	_____
_____	_____	_____	_____

9. WATER LEVEL  
 Static water level 73 feet below land surface  
 Flow 25 G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A & H PUMP CO.  
 Address Carson City, NV 89701  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada contractor's driller's number issued by the Division of Water Resources \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1674  
 Signed John B. Burt  
 By driller performing actual drilling on site or contractor  
 Date 4/22/91