WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36195
Permit No.
Basin 103

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17613

1. OWNER Comstock Bank
MAILING ADDRESS 901 N. Stewart St. Carson City NV 89701
ADDRESS AT WELL LOCATION No Address Assigned yet Lot 4 TRINA CIR Stagecoach

2. LOCATION NW ¼ NW ¼ Sec. 2 T. 17 N/S R. 22 E. Lyon County
PERMIT NO. (Issued by Water Resources) 15-411-67 (Parcel No.) Stagecoach Sub (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	8	8
Sandy Gravel		8	10	2
Sand, gravel with Clay streaks		10	76	66
Coarse Sand	—	76	82	6
Brown Sandy Clay		82	96	14
Coarse Sand + gravel		96	120	24
Sandy Clay	—	120	131	9
Sand, gravel, clay streaks		131	150	19

'91 APR 22 A9 02
RECEIVED
STATE ENGINEERS OFFICE

Date started April 18, 1991
Date completed April 19, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
N/A	N/A	N/A	N/A

BAILER TEST Air Lift
G.P.M. 20 at time of lift Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 5/8 inches Total depth 150 feet
..... inches
..... inches
Casing record 1 foot above ground to 150'
Weight per foot N/A Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	150 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement grout
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 150 feet

Perforations:
Type perforation Factory Milled
Size perforation
From 110 feet to 150 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 74 feet below land surface
Flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality clear at time of Lift

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling (Contractor)
Address PO Box 1345 Dayton NV (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 4739 A
Nevada contractor's driller's number issued by the Division of Water Resources 249
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 590
Signed [signature] By driller performing actual drilling on site or contractor
Date 4-19-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627