WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36198
Permit No.
Basin 102

1. OWNER Dave Gilbert ADDRESS 5215 Nectarine St. Silver Springs Nv. 89429
Parcel # 17-091-04 Lot # 228 Mountain View Sub # 2
2. LOCATION NE ¼ SE ¼ Sec. 5 T. 17 N/S R. 25 E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fine sand		0	12	12
Brown clay + Some sand ?		12	65	53
gray clay		65	70	5
Fine gray sand	X	70	100	30
corse sand	X	100	124	24

91 APR -9 A9:17 STATE ENGINEER'S OFFICE

Date started 4-6, 1991
Date completed 4-7, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 18 Draw down 5 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 11" inches Total depth 124 feet
Casing record 6 5/8 O.D.
Weight per foot Thickness 188

Diameter	From	To
6 5/8 O.D. inches	+ 1 feet	124 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 124 feet

Perforations:
Type perforation Mill
Size perforation 3/16 X 3
From 104 feet to 124 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 40 Feet below land surface
Flow G.P.M.
Water temperature cold F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ace Drilling & Development
Address P.O. Box 668 Silver Springs Nv. 89429
Nevada contractor's license number 14299
Nevada driller's license number 726
Signed [signature]
Date 4-8-91

USE ADDITIONAL SHEETS IF NECESSARY

5471