WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36205
Permit No.
Basin 87

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 11806

1. OWNER Dr. Duxbury
MAILING ADDRESS 1 Booth St. Reno, Nev.
ADDRESS AT WELL LOCATION 14403 S. Virginia St. Reno, Nev.

2. LOCATION N 1/2 N/W 1/4 Sec. 29 T. 18 N N/S R. 20 E Washoe County
PERMIT NO. ____ Issued by Water Resources | 49-381-15 Parcel No. | Subdivision Name

3. TYPE OF WORK
New Well ☐ Recondition ☐
Deepen ☐ ~~Other~~ abandonment ☑

4. PROPOSED USE
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☑ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Well #1 Behind house near creek, 8" 87' deep Bottom to surface w/ 54 cubic feet Neat cement, perforated w/ mills Knife 48' to surface				
Well #2 is located at entrance of driveway just off White Creek Rd. By creek 12" well 99' deep, perforated w/ mills Knife 48' to surface + pumped 92 cubic ft. of Neat from bottom to surface				
Well #3 300' off White Creek Rd. at far lower corner of property 8" well 85' deep, perforated w/ mills Knife from 48' to surface + pumped 4 yards neat cement + 2 yards of 8 sac mix sand + cement from Bottom up to 30' topped off on outside of 8" top 30'				
Water resourceses was present when sealing all 3. wells				

Date started 4-22, 1991
Date completed 4-24, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter hole ____ inches Total depth ____ feet
Casing record ____
Weight per foot ____ Thickness ____

Diameter	From	To
#1 8 5/8 x 156 inches	0 feet	87 feet
inches	feet	feet
#2 inches	feet	feet
12 3/4 x 1/4 inches	0 feet	99 feet
#3 inches	feet	feet
8 5/8 x 188 inches	0 feet	85 feet

Surface seal: Yes ☑ No ☐ Type NEAT
Depth of seal ____ feet
Gravel packed: Yes ☐ No ☐
Gravel packed from ____ feet to ____ feet

Perforations:
Type perforation Mills Knife 3 rows 8"
Size perforation 8" wells 1/4 x 1 1/2" 12" 1/2 x 1 1/2" x 4
From ____ feet to ____ feet
From 0-48 feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level ____ feet below land surface
Flow ____ G.P.M. ____ P.S.I.
Water temperature ____ ° F. Quality ____

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Paul Williams & Sons
Contractor
Address 14 Lilac Ln Reno Nev 89512
Contractor
Nevada contractor's license number 14483
Nevada contractor's drillers number 957
Nevada driller's license number 957
Actual Driller
Signed Paul E. Williams
Contractor
Date 4-26-91

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434