WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

OFFICE USE ONLY
Log No. 36710
Permit No.
Basin 102

WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Richard Payton ADDRESS 4030 Margie ST. 89429
P.O. Box 605 Silver Springs Nev.
Parcel # 18-043-04
2. LOCATION SW ¼ SW ¼ Sec. 15 T. 18 N/S R. 25 E. Lyon County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay, corse sand + some cobble stones		0	30	30
corse sand, + some Brown clay		30	75	45
Brown clay, some sand + cobble stones		75	155	80
corse sand	X	155	200	45

Date started 4-2, 1991
Date completed 4-4, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 18 Draw down 3 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter hole 11" inches Total depth 200 feet
Casing record 6 5/8 O.D.
Weight per foot Thickness 188

Diameter	From	To
6 5/8 inches	+2 feet	200 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 0-50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 200 feet

Perforations:
Type perforation Mill
Size perforation 3/16 x 3
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 82 Feet below land surface
Flow G.P.M.
Water temperature cold° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Ace Drilling + Development
Address P.O. Box 668 Silver Springs Nv. 89429
Nevada contractor's license number 14299
Nevada driller's license number 726
Signed H. L. Lyle Jr.
Date 4-6-1991

USE ADDITIONAL SHEETS IF NECESSARY

5471