

OFFICE USE ONLY
 Log No. 36251
 Permit No. 53753 5724
 Basin 5-76
 15103

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15103
 ADDRESS AT WELL LOCATION 1 Mile So. of Fernley

1. OWNER V.T. Mc Cold ADDRESS AT WELL LOCATION 1 Mile So. of Fernley
 MAILING ADDRESS P.O. Box 1148 West side of highway 1/2 mile
Fernley, NV Fernley, NV
 2. LOCATION NE 1/4 NE 1/4 Sec 26 T. 20 N3 R. 24 E. Lyon County
 PERMIT NO. 53753 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Volcanic rock		415	418	
Gray Shale		418	597	
Gray sandstone		597	604	
Gray Shale		604	680	

No water encountered between 415 and 680.
 No casing set below 415', Plugged back to 415' with cavings from 680' to 600' and super gel from 600' to 415'

This well is believed to be destroyed. See 14r of 2/8/12 in Permit files
 63161 : 63162
 -Sivachan-
 7/14/12

Deepening of log # 33300

8. WELL CONSTRUCTION
 Diameter 7 7/8" inches Total depth 680 feet
 _____ inches
 _____ inches

Casing record _____
 Weight per foot _____ Thickness _____

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type _____
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation Mechanical Slot
 Size perforation 1" x 1/2"
 From 80 feet to 120 feet
 From 140 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 4-3-91, 19____
 Date completed 4-15-91, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air ~~BAKER~~ TEST
 G.P.M. 8 Draw down 415 feet 2 hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 135 feet below land surface
 Flow none G.P.M. none P.S.I.
 Water temperature cool °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Drilling Research Contractor
 Address P.O. Box 8056 Reno NV Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0027791c-23
 Nevada contractor's driller's number issued by the Division of Water Resources 873
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
 Signed Bruce Miller
 By driller performing actual drilling on site or contractor
 Date 4-18-91