WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36257
Permit No.
Basin 92 A

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15386

1. OWNER: SPRING CREEK BUILDERS
MAILING ADDRESS: 245 Vine Street, Reno, NV 89503
ADDRESS AT WELL LOCATION: 10925 Silver Knolls Blvd., Reno, NV 89506

2. LOCATION: SW ¼ SW ¼ Sec. 24 T. 21N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 86-203-23 (Parcel No.) Silver Knolls (Subdivision Name)

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Tan sandy clay		2	22	20
Brown sandy clay		22	93	71
Soft zone		93	94	1
Brown clay, med. hard		94	102	8
Brown clay with soft streaks		102	162	60
Sand	X	162	170	8
Clay with sand streaks		170	202	32
Soft zone		202	206	4
Clay		206	225	19
Decomposed granite with some small gravel	X	225	247	22
Decomposed granite with soft zones		247	253	6
Soft zone		253	260	7

Date started 4-23-91, 19
Date completed 4-24-91, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 8 5/8 inches, 10 inches, inches — Total depth 260 feet; 0 to 50 ft
Casing record 260' steel casing installed.
Weight per foot Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	260 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 260 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 175 feet to 255 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 156 feet below land surface
Flow 18 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 908
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 29, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627