WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36262
Permit No.
Basin 84

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 15405

1. OWNER DON RAMAGE
MAILING ADDRESS P.O. Box 491, Verdi, NV 89439
ADDRESS AT WELL LOCATION Chantry Flats Road, Reno, NV 89510

2. LOCATION NE ¼ SW ¼ Sec. 1 T. 21N N/S R. 21 E. Washoe County
PERMIT NO. ____ (Issued by Water Resources) 77-190-05 (Parcel No.) Palomino Valley (Subdivision Name)

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [X] Irrigation [ ] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [ ] Rotary [X]
Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	2	2
Brown clay with boulders		2	16	14
Yellow clay		16	85	69
Green clay		85	96	11
Gray clay		96	132	36
Soft zone (NO WATER)		132	135	3
Gray clay		135	168	33
GReen clay		168	202	34
Gray clay		202	243	41
Light green clay		243	263	20
Gray clay		263	341	78
Black volcanic rock		341	361	20
Fractured volcanic rock X		361	393	32
Black volcanic rock		393	400	7
* Water not cold but not warm.				

Date started 4-9-91, 19
Date completed 4-11-91, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 8 5/8 inches Total depth 400 feet
10 inches 0 to 50 ft
inches
Casing record 400' steel casing installed
Weight per foot ____ Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	400 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 51 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 51 feet to 400 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 354 feet to 394 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 125 feet below land surface
Flow 20 G.P.M. ____ P.S.I.
Water temperature * °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370, Reno, NV 89510 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 12, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627