WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36264
Permit No.
Basin 924

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13922

1. OWNER Fern Bladerston
MAILING ADDRESS P.O. Box 71583
Reno-Nev 89570
ADDRESS AT WELL LOCATION 15015 Red Rock Rd.

2. LOCATION NW ¼ ~~SW~~ ¼ Sec. 20 T. 22 N/S R. 19 E. Washoe County
PERMIT NO. ~~[illegible]~~ Issued by Water Resources | 79-341-04 Parcel No. | Red Rock Estates #12 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Clay		0'	10'	
Fractured Rock		10'	60'	
Hard Rock		60'	160	
Fractured Rock		160'	190'	
Shelly Grey Limestone		190	220	
Yellow Limestone	220	220	240	20'
Grey Limestone		240	250	
Yellow Limestone	250	250	260	10'
Grey Limestone		260	280	
Fractured Rock	280	280	300	20'
Fractured Rock	305	300	320	15'
Yellow Limestone		320	340	
TD				

Date started 4-27-91, 19 91
Date completed 4-30-91, 19 91

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
Air Lift	40 gpm	1.5 hr.	

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 12¼ inches Total depth 340 feet
8¾ inches (12¼" to 50FT
inches (8¾" 50-340FT)
Casing record
Weight per foot Thickness

Diameter	From	To
6" inches	-1 feet	340 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Grout
Depth of seal 50' feet
Gravel packed: Yes ☑ No ☐
Gravel packed from 50 feet to 340 feet

Perforations:
Type perforation ~~1/8" x 8"~~ Trench
Size perforation 1/8" x 8"
From 340' feet to 220 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 220 feet below land surface
Flow 40 G.P.M. 50 P.S.I.
Water temperature 55 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Blaine Drilling & Pump (Contractor)
Address Carson City Nv. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 10950
Nevada contractor's driller's number issued by the Division of Water Resources 1118
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1743
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 4-30-91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627