

OFFICE USE ONLY
 Log No. 36286
 Permit No. _____
 Basin. 84
 NOTICE OF INTENT NO. 17257

WELL DRILLER'S REPORT
 Please complete this form in its entirety

PRINT OR TYPE ONLY *14CWA*

1. OWNER DAN MARTIN ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 4755 Wildhorse
Reno, NV 89510
 2. LOCATION NE 1/4 SW 1/4 Sec. 14 T. 22N N/S R. 21 E Washoe County
 PERMIT NO. 77-120-0507 Palomino Valley Dist 1 14-2-1-9
Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL DEEPENING				
Found heavy drill mud in hole to bottom, from 178 ft. GPM test 2 GPM at bottom.				
Red volcanic rock		263	303	40
Soft zone (app 2 GPM)	X	303	310	7
Red volcanic rock		310	345	35
Fracture (NO WATER)		345	346	1
Red volcanic rock		346	348	2
Black volcanic rock		348	380	32
White clay		380	391	11
Brown volcanic rock		391	425	34

8. WELL CONSTRUCTION
 Diameter 6 1/8 inches Total depth 425 feet
 _____ inches
 _____ inches
 Casing record 425' steel casing installed.
 Weight per foot _____ Thickness .188

Diameter	From	To
<u>5" OD</u> inches	<u>0</u> feet	<u>425</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes No Type N/A
 Depth of seal _____ feet
 Gravel packed: Yes No
 Gravel packed from 260 feet to 425 feet
 Perforations:
 Type perforation factory sawed slot perforations
 Size perforation 3/32 x 3 x 5 around
 From 185 feet to 205 feet
 From 305 feet to 325 feet
 From 405 feet to 425 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 4-10-91, 19____
 Date completed 4-13-91, 19____

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL
 Static water level 75 feet below land surface
 Flow 4 G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
Contractor
 Address P.O. Box 12370, Reno, NV 89510
Contractor
 Nevada contractor's license number issued by the State Contractor's Board 22549
 Nevada contractor's driller's number issued by the Division of Water Resources 908
 Nevada driller's license number issued by the Division of Water Resources the on-site driller 923
 Signed [Signature]
By driller performing actual drilling on site or contractor
 Date April 16, 1991