WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36275
Permit No.
Basin 45

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 14741

1. OWNER Alice Tybo / South Fork Band Council
MAILING ADDRESS P.O. Box 1736 Elko NV 89801
ADDRESS AT WELL LOCATION Rural Lee, NV

2. LOCATION SE ¼ NW ¼ Sec. 19 T. 31 N/S R. 57 E. Elko County
PERMIT NO. — (Issued by Water Resources) Parcel No. None, on Res. Subdivision Name Edna Tybo allotment

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	10	
DK. Brown Clay		10	18	
& Gravel				
Granite Boulders		18	30	
semi con				
Alt. Layers Large		30	75	
granite Boulders +				
Con. gravels				
DK Brown sands		75	80	
+ silts				
Granite boulders		80	100	
Brown Sand	✓	100	110	
Granite boulders + gravel		110	180	
Brown sand	✓	180	190	
Granite boulders		190	227	

Date started Mar. 28, 1991
Date completed Apr. 5, 1991

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 227 feet
..... inches
..... inches
Casing record
Weight per foot ..... Thickness .188

Diameter	From	To
6 5/8 inches	+2 feet	227 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 227 feet

Perforations:
Type perforation Air
Size perforation 1/8 x 1
From 100 feet to 120 feet 2 rows perf
From 200 feet to 220 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 75 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name R.D. Reynolds Drilling (Contractor)
Address Box 402 Wells NV 89835 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 014410
Nevada contractor's driller's number issued by the Division of Water Resources 1390
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1585
Signed Russell F. Boley
By driller performing actual drilling on site or contractor
Date 4/12/91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627