WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36299
Permit No.
Basin 33

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 17328

1. OWNER Town of Orovada; Gerhardt & Berry Construction P.O. Box 7637 Reno, NV. 89510
MAILING ADDRESS
ADDRESS AT WELL LOCATION No physical Address at this Site

2. LOCATION NE ¼ NE ¼ Sec. 34 T. 43 N/S R. 37 E. Humboldt County
PERMIT NO. Wavier 10-360 (Issued by Water Resources) | Wavier 10-360 (Parcel No.) | "NA" (Subdivision Name)

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE Monitoring
Domestic ☐ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☒
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	3	
Pea Gravel		3	5	
Clay w/s Sand		5	10	
Pea Gravel		10	30	
Clay		30	35	
Clay		35	41	
Clay w/s Sand & Gravel		41	65	
Clay & Sand Stringers		65	85	
Clay w/s Sand		85	110	
Sand & Gravel w/s Clay		110	125	
Rock & Gravel w/s Clay		125	128	
Rock & Gravel & Clay		128	145	
Clay & Gravel w/s Sand		145	180	
Clay w/s Sand		180	192	

Replaced by Well Log # 116652
Plugged by Well Log # 115969

'91 APR 25 AM 11:36
STATE ENGINEER'S OFFICE

Date started 4-1-91, 19
Date completed 4-23-91, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Lift @ 156 PM

BAILER TEST
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 10 inches Total depth 192 feet
inches
inches
Casing record
Weight per foot Thickness SCH. 80 PVC

Diameter	From	To
6 inches	+1 feet	192 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 140 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 192 feet to 145 feet
145 TO 140 Bentonite Pellets
Perforations:
Type perforation Slot
Size perforation .125
From 183 feet to 154 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 100 feet below land surface
Flow 4.5 G.P.M. P.S.I.
Water temperature °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name American Drilling (Contractor)
Address P.O. Box 1878 Winnemucca, NV. 89445 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0020578
Nevada contractor's driller's number issued by the Division of Water Resources 1161
Nevada driller's license number issued by the Division of Water Resources, the on-site driller -730
Signed [signature] (By driller performing actual drilling on site or contractor)
Date April 23, 1991

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627