WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

In Book

OFFICE USE ONLY
Log No. 36318
Permit No. 56855
Basin 216

NOTICE OF INTENT NO.

1. OWNER Georgia Pacific
MAILING ADDRESS 133 Peachtree St. N.E.
Atlanta, Ga. 30303

ADDRESS AT WELL LOCATION
Apex Plant

2. LOCATION SE ¼ NE ¼ Sec. 34 T. 18 N/S R. 63 E. Clark County
PERMIT NO. 55275-T
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☒ Other Temporary

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☒ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
install temporary casing				
in test well for emergency				
use only				

RECEIVED
FEB 14 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8/19, 19 90
Date completed 8/19, 19 90

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Submersible			
pump	130	unkown	72

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	? Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	10.78	.156	0	960

Perforations:
Type perforation Torch
Size perforation 1/4 x 6" 3 around
From 840 feet to 960 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☐ Yes ☒ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 608 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Allen Drilling, Inc. (Contractor)
Address 4847 So. Valley View Blvd. (Contractor)
Las Vegas, Nev. 89108
Nevada contractor's license number issued by the State Contractor's Board 0018916=0018917
Nevada driller's license number issued by the Division of Water Resources, the on-site driller
Signed Fred B. Allen III
By driller performing actual drilling on site or contractor
Date 2-12-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627