WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36330
Permit No.
Basin 162

NOTICE OF INTENT NO. 8075

1. OWNER Fred Craug
MAILING ADDRESS
ADDRESS AT WELL LOCATION Florenza St.

2. LOCATION SE ¼ SW ¼ Sec. 28 T. 19S N/S R. 53 E. Nye County
PERMIT NO. N/A (Issued by Water Resources) | 29-132-13 (Parcel No.) | Rancho Paradiso Unit 1 Lot 20 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	12'	12'
Caliche		12'	14'	2'
Clay		14'	56'	42'
Clay + gravel		56'	61'	5'
Clay		61'	76'	15'
Clay + gravel		76'	80'	4'
Clay		80'	86'	6'
Clay + gravel		86'	88'	2'
Clay		88'	91'	3'
Clay + gravel		91'	94'	3'
Clay		94'	96'	2'
Sandstone	WB	96'	98'	2'
Clay		98'	100'	2'
Sandstone	WB	100'	106'	6'
Clay		106'	110'	4'
Sandstone	WB	110'	112'	2'
Clay		112'	123'	11'
Sandstone	WB	123'	125'	2'
Clay		125'	134'	9'
Sandstone	WB	134'	136'	2'
Clay		136'	142'	6'
Sandstone	WB	142'	144'	2'
Clay		144'	148'	4'
Sandstone	WB	148'	151'	3'
Clay		151'	153'	2'
Sandstone	WB	153'	155'	2'
Clay		155'	160'	5'

Date started 11-13, 1991
Date completed 11-16, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

NOV 25 1991

8. WELL CONSTRUCTION
Depth Drilled 160' Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12¼ Inches	0' Feet	160' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	160'

Perforations:
Type perforation Sawcut
Size perforation 1/8 x 3
From 140 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 160' feet to 50' feet

9. WATER LEVEL
Static water level 94 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Sum (By driller performing actual drilling on site or contractor)
Date 11-20-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627