

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9313

1. OWNER Mike Smith ADDRESS AT WELL LOCATION Tough Boy  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION NE 1/4 SE 1/4 Sec. 31 T. 19S N/S R. 53 E Nye County  
 PERMIT NO. N/A Issued by Water Resources Parcel No. 29-522-04 Subdivision Name Gooseneck Park Lot 74

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	22'	22'
Caliche		22'	27'	5'
Clay		27'	34'	7'
Caliche		34'	36'	2'
Clay		36'	53'	17'
Caliche	WB	53'	57'	4'
Clay		57'	64'	7'
Caliche	WB	64'	69'	5'
Clay		69'	83'	14'
Caliche	WB	83'	88'	5'
Clay		88'	97'	9'
Caliche	WB	97'	106'	9'
Clay		106'	117'	11'
Caliche	WB	117'	126'	9'
Clay		126'	136'	10'
Caliche	WB	136'	140'	4'

8. WELL CONSTRUCTION  
 Depth Drilled 140' Feet Depth Cased 140' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 140' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0'</u>	<u>140'</u>

Perforations:  
 Type perforation Sawcut  
 Size perforation 1/8 x 3  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 140' feet to 50' feet

9. WATER LEVEL  
 Static water level 42 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 12-18, 1991  
 Date completed 12-21, 1991

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling  
 Address HCR 78 Box 80358  
Pahrump, NV. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dan  
 By driller performing actual drilling on site or contractor  
 Date 12-23-91

