

Log No. 36342
 Permit No. _____
 Basin _____

CORRECTED COPY
PRINT OR TYPE ONLY

WELL DRILLER'S REPORT
 Please complete this form in its entirety

NOTICE OF INTENT NO. 5626

1. OWNER Ray Henrickson ADDRESS AT WELL LOCATION 6532 Deer Springs
 MAILING ADDRESS 5685 W. Spring Mountain Rd.
Las Vegas, NV 89102

2. LOCATION (SE) 1/4 (NW) 1/4 Sec (23) T 19 N 60 E Clark County
 PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Caliche		0	40	40
Brown, sandy clay		40	60	20
White clay & sand		40	100	40
Brown, sandy clay		100	160	60
White, sandy clay		160	200	40
White, sandy clay, some gravel		200	220	20
Gravel		220	240	20
Sand & clay		240	260	20
Clay		260	380	120
Gravel & clay		380	400	20
Clay		400	420	20
Gravel & clay		420	440	20
Clay		440	520	80
Clay & gravel		520	540	20
Clay		540	560	20
Hard clay & gravel mixed		560	585	25

8. WELL CONSTRUCTION

Diameter 12 inches Total depth 585 feet

Casing record _____
 Weight per foot _____ Thickness 188

Diameter	From	To
<u>8</u> inches	<u>+1</u> feet	<u>582</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 205 feet
 Gravel packed: Yes No
 Gravel packed from 205 feet to 585 feet

Perforations:
 Type perforation Milled slots
 Size perforation 1/8" slots
 From 383 feet to 582 feet
 From _____ feet to _____ feet

Date started January 5, 1989
 Date completed January 10, 1989

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 80 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name THOMPSON DRILLING CO., INNC.
4185 West Harmon Contractor
Las Vegas, NV 89103
 Contractor

Nevada contractor's license number issued by the State Contractor's Board 4286A
 Nevada contractor's driller's number issued by the Division of Water Resources 290
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1489
 Signed Richard T. Thompson
 By driller performing actual drilling on site or contractor
 Date November 13, 1991

RECEIVED
 NOV 21 1991
 Div. of Water Resources
 Branch Office - Las Vegas, NV

