

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Log No. 36359  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_  
 NOTICE OF INTENT NO. 9325

1. OWNER John Cafeo ADDRESS AT WELL LOCATION Fitz St  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SE 1/4 NE 1/4 Sec. 24 T. 20S N/S R. 52 E Nye County  
 PERMIT NO. N/A 28-782-28 Charleston Park Ranches Lot 727 Un. 6  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0'	19'	19'
Caliche		19'	24'	5'
Clay		24'	31'	7'
Caliche		31'	41'	10'
Clay		41'	55'	14'
Caliche	WB	55'	58'	3'
Clay		58'	66'	8'
Caliche	WB	66'	71'	5'
Clay		71'	77'	6'
Caliche	WB	77'	79'	2'
Clay		79'	88'	9'
Caliche	WB	88'	91'	3'
Clay		91'	106'	15'
Caliche	WB	106'	109'	3'
Clay		109'	116'	7'
Caliche	WB	116'	121'	5'
Clay		121'	128'	7'
Caliche	WB	128'	136'	8'
Clay		136'	140'	4'

8. WELL CONSTRUCTION  
 Depth Drilled 140' Feet Depth Cased 140' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0' To 140'  
12 1/2 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0'</u>	<u>140'</u>

Perforations:  
 Type perforation sawcut  
 Size perforation 1/8 x 3  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 140' feet to 50' feet

9. WATER LEVEL  
 Static water level 44' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling  
Contractor  
 Address HCR 78 Box 80358  
Contractor  
Pahrump, Nv. 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dew  
By driller performing actual drilling on site or contractor  
 Date 12-23-91

Date started 12-20 1991  
 Date completed 12-21 1991

7. WELL TEST DATA

TEST METHOD:	TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift		
	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)