

Log No. 36360  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9376

1. OWNER Fred McGary ADDRESS AT WELL LOCATION Fritz St  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SE 1/4 NE 1/4 Sec 24 T. 20S N1S R. 52 E County Wye  
 PERMIT NO. \_\_\_\_\_  
 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name Charleston Park Ranch's Lot 133 Uub

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0'	19'	19'
Caliche		19'	22'	3'
Clay		22'	31'	9'
Caliche		31'	41'	10'
Clay		41'	55'	14'
Caliche	WB	55'	58'	3'
Clay		58'	66'	8'
Caliche	WB	66'	71'	5'
Clay		71'	77'	6'
Caliche	WB	77'	79'	2'
Clay		79'	88'	9'
Caliche	WB	88'	91'	3'
Clay		91'	106'	15'
Caliche	WB	106'	109'	3'
Clay		109'	116'	7'
Caliche	WB	116'	121'	5'
Clay		121'	128'	7'
Caliche	WB	128'	136'	8'
Clay		136'	140'	4'

8. WELL CONSTRUCTION  
 Depth Drilled 140' Feet Depth Cased 140' Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.94</u>	<u>.188</u>	<u>0'</u>	<u>140'</u>

Perforations:  
 Type perforation Sawcut  
 Size perforation 1/8 x 3  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 140' feet to 50' feet

9. WATER LEVEL  
 Static water level 49 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas  
 By driller performing actual drilling on site or contractor  
 Date 12-23-91

7. WELL TEST DATA

TEST METHOD:	Bailer	Pump	Air Lift
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

RECEIVED  
 DEC 26 1991

Div. of Water Resources  
 Branch Office Las Vegas, NV  
 Date completed 12-20 1991  
12-21 1991