

OFFICE USE ONLY  
 Log No. 36365  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9382

1. OWNER Lee Calhoon ADDRESS AT WELL LOCATION Jill St.  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NW 1/4 NE 1/4 Sec. 6 T. 20S N/S R. 53 E Dye County  
 PERMIT NO. N/A | 36-023-14 | Landmark Subdivision Lot 30 BIK B  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0'	17'	17'
caliche		17'	19'	2'
Clay		19'	31'	12'
caliche		31'	34'	3'
Clay		34'	46'	12'
caliche		46'	51'	5'
Clay		51'	63'	12'
caliche	WB	63'	67'	4'
Clay		67'	78'	11'
caliche	WB	78'	83'	5'
Clay		83'	92'	9'
caliche	WB	92'	98'	6'
Clay		98'	103'	5'
caliche	WB	103'	118'	15'
Clay		118'	124'	6'
caliche	WB	124'	129'	3'
Clay		129'	138'	11'
caliche	WB	138'	140'	2'

8. WELL CONSTRUCTION  
 Depth Drilled 140' Feet Depth Cased 140' Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 140' Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	140'

Perforations:  
 Type perforation sawcut  
 Size perforation 1/8 x 3  
 From 120 feet to 140 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 140' feet to 50' feet

**RECEIVED**

JAN 17 1992

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 1-7, 1992  
 Date completed 1-11, 1992

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 48 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling  
 Address HCR 78 Box 80358  
Pahrump, NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dam  
 By driller performing actual drilling on site or contractor  
 Date 1-13-92