WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36383
Permit No. 56802
Basin

NOTICE OF INTENT NO. 8494

1. OWNER Clark M. & Patricia A. Thomas
MAILING ADDRESS
ADDRESS AT WELL LOCATION Charleston Park Ave./East Ford Loop

2. LOCATION SE ¼ SW ¼ Sec. 17 T. 20-S N/S R. 53 E. Nye County
PERMIT NO. ~~55030~~ 56802 (Issued by Water Resources) 2(MapFile 091261) (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Grey clay/caliche | | 4 | 18 | 14 |
| Grey clay | X | 18 | 75 | 57 |
| Brown clay | X | 75 | 200 | 125 |

RECEIVED
DEC 03 1991
Div. of Water Resources
Branch Office, Las Vegas, NV

Date started November 17, 1991
Date completed November 18, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 4 | ¼ |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | 0 Feet | 200 Feet | |
| Inches | Feet | Feet | |
| Inches | Feet | Feet | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | 0 | 200 |

Perforations:
Type perforation Torch Cut
Size perforation ¼ in. width 8 in. long
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 45 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Jim Pike Well Drilling (Contractor)
Address P.O. Box 56 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324
Signed (By driller performing actual drilling on site or contractor)
Date November 25, 1991

(Rev. 3-91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627