WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36393
Permit No.
Basin 212

NOTICE OF INTENT NO. 8449

1. OWNER HARDING LANSON
MAILING ADDRESS 2300 Paseo del Prado
LAS VEGAS NEVADA.

ADDRESS AT WELL LOCATION UNOCAL 76
DECATUR & EXPRESSWAY
LAS VEGAS, NEVADA.

2. LOCATION SE ¼ SE ¼ Sec. 25 T. 20 N(S) R 60 E CLARK County

PERMIT NO. M0-2103 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Concrete		0	.4	.4
gravelly Sand		.4	3.0	2.6
Silty clay w/ gravel Sand		3.0	6.0	3.0
Sandy clay w/ gravel		6.0	7.5	1.5
Sandy clay w/ cinder rock		7.5	8.5	1.0
Sandy clay w/ gravel		8.5	9.5	1.0
Silty clay w/ gravel		9.5	11.5	2.0
gravelly clay w/ Sand		11.5	13	1.5
Silty clay w/gravel		13	16	3.0
clayey sand		16	23	13
T.D. 23'				

RECEIVED FEB 28 1992 Div. of Water Resources Branch Office - Las Vegas, NV

Date started Nov. 14, 1991
Date completed Nov. 14, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 23.5 Feet Depth Cased 23 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
10	0	23.5

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	21bs	SCH. 40	0	23

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 8 feet to 23 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-6 / 4-6 Bent.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout w/ Bent.
Gravel Packed: ☒ Yes ☐ No
From 6 feet to 23 feet

9. WATER LEVEL
Static water level 13' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LEBLANC (Contractor)
Address 4670 S. POLARIS (Contractor)
LAS VEGAS NEVADA 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589 T. 1
Signed R. LeBlanc (By driller performing actual drilling on site or contractor)
Date 2-26-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O) 627