WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36403
Permit No.
Basin

NOTICE OF INTENT NO. 9495

1. OWNER Broadbent & [illegible]
MAILING ADDRESS 833 Nevada Hwy
Boulder City Nevada

ADDRESS AT WELL LOCATION Charleston & Upland

2. LOCATION SE ¼ SW ¼ Sec. 36 T. 20 N/S R. 60 E. County

PERMIT NO. M 02126 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown silky sand		0	2	
Caliche		2	3	
Lt. gray clay		3	6	
Caliche		6	9	
Brown silty sand w/ gravel		9	42	
Reddish Brown silt sand w/ clay & gravel		42	52	
Lt Gray sandy clay w/ gravel wet		52	70	

RECEIVED
FEB 27 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Feb 18, 1992
Date completed Feb 18, 1992

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 70 Feet Depth Cased 70 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	70 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	.7 Lbs	SCH 40	0	70

Perforations:
Type perforation Factory Slotted
Size perforation 0.020
From 45 feet to 70 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-28-30 Beat
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout W Bent

Gravel Packed: ☑ Yes ☑ No
From 30 feet to 70 feet

9. WATER LEVEL
Static water level 55.2 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Donald J. Wilson (Contractor)
Address 4670 S Polaris (Contractor)
Las Vegas N.V. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589
Signed Donald J. Wilson
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627