WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36404
Permit No.
Basin 212

NOTICE OF INTENT NO. 8228

1. OWNER Mr. Bill Kuhn MAGIC WAND TRUCK STOP
MAILING ADDRESS 1100 E. Colton Ave. N. Las Vegas, NV 89030
ADDRESS AT WELL LOCATION 1100 E. COLTON AVE North Las Vegas, NV 89030

2. LOCATION NW ¼ SE ¼ Sec. 11 T. 20 S N(S) R 61 (E) CLARK County
PERMIT NO. MO-2077 (Issued by Water Resources) Parcel No. PERMIT #0572 NLV OFFSITE CONSTRUCTION (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT SURFACE		0	4"	4"
SANDY GRAVEL (GM)		4"	4.0'	4'
CLAYEY SILT (ML)		4'	7'	3'
SANDY SILT (ML)		7'	11'	4'
SILTY CLAY (CL)		11'	14'	3'
CLAYEY SILT (ML)		14'	16'	2'
SANDY SILT (ML)		16'	19'	3'
CALICHE		19'	20'	1'
SILTY CLAY (CL) w/GRVL		20'	26'	6'
CLAY (CLAY) w/SILT		26'	36'	10'
CALICHE		36'	42'	6'
CLAYEY SILT (ML)		42'	49'	7'
SILTY CLAY (ML-CL)		49'	60'	11'

TD = 60'

RECEIVED
FEB 14 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 7-5, 1991
Date completed 7-5, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)
6 Inches From 0 Feet To 60 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2 INCH	.7 lb.	Sch. 40 PVC	0	60

Perforations:
Type perforation Factory Slotted Screen
Size perforation 0.020 INCH
From 40 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 28'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 30' feet to 60' feet

9. WATER LEVEL
Static water level 48.0 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON/CONVERSE CONSULTANTS (Contractor)
Address 4670 S. Polaris Ave (Contractor)
Las Vegas, Nevada 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed Don Wilson (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627