WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

in Book IC

OFFICE USE ONLY
Log No. 36421
Permit No.
Basin 212

NOTICE OF INTENT NO. 9472

1. OWNER Anderson Dairy
MAILING ADDRESS c/o Broadbent & Assoc. 833 Nevada Hwy, Boulder City
ADDRESS AT WELL LOCATION Anderson Dairy Searles Ave. Las Vegas, NV.

2. LOCATION NW ¼ NW ¼ Sec. 26 T 20 N (S) R 61 (E) County

PERMIT NO. Mo 2116 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Fill - Sandy gravel | | 0 | 1.0 | 1.0 |
| Silty Sand w/gravel | | 1.0 | 6.0 | 5.0 |
| Sandy clay | | 6.0 | 12.0 | 6.0 |
| part. Cemented gravel | | 12.0 | 15.0 | 3.0 |
| Sandy clay | | 15.0 | 25.0 | 10.0 |
| part. cemented gravel | | 25.0 | 30.5 | 5.5 |

RECEIVED
FEB 14 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Dec. 18, 1991
Date completed Dec. 18, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 30.5 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 8" Inches | | 0 Feet | 30.5 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | .7 lbs | Sch 40 | 0 | 30 |
| | | | | |
| | | | | |

Perforations:
Type perforation Factory Slotted
Size perforation 0.020
From 5 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-4'/2'-4' Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout w/ Bent.
Gravel Packed: ☑ Yes ☐ No
From 4' feet to 30' feet

9. WATER LEVEL
Static water level 14.70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard LeBlanc
Contractor
Address 4670 S. Polaris
Contractor
Las Vegas, NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589-T1
Signed R. LeBlanc
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627