WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 3042B
Permit No.
Basin 212-LAB

NOTICE OF INTENT NO. 8413

1. OWNER The Southland Corporation
MAILING ADDRESS 7167 S. Alton Way Englewood, CO 80112
ADDRESS AT WELL LOCATION 529 N. Rancho Drive Las Vegas, NV 89107

2. LOCATION SW ¼ SE ¼ Sec. 29 T. 20 N/S R. 61 E. Clark County
PERMIT NO. M/D-352 A (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Gravel		0'	1'	1'
Gravelly Sand		1'	3'	2'
Sandy Silt		3'	4.5'	1.5'
Silty Clay	X	4.5'	14.5'	10'
Caliche	X	14.5'	17'	2.5'
Silty Clay	X	17'	18'	—

RECEIVED 91 DEC 12 AM 11:51 STATE ENGINEERS OFFICE

Date started 8-29, 1991
Date completed 8-29, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
	NA	

8. WELL CONSTRUCTION
Depth Drilled 18 Feet Depth Cased 18 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	18 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5		0.474	0	18

Perforations:
Type perforation Machine Slotted - PVC
Size perforation 0.020 - inch
From 3 feet to 18 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 1 Foot
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 1 feet to 18 feet

9. WATER LEVEL
Static water level 10.20 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality Poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) WT Environmental Consultants Inc
Address (Contractor) 3611 W. Tompkins Ave. Las Vegas, NV 89103
Nevada contractor's license number issued by the State Contractor's Board 0033048
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1761
Signed (By driller performing actual drilling on site or contractor)
Date 12-5-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627