WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36434
Permit No.
Basin 212

NOTICE OF INTENT NO. 9462

1. OWNER TEXACO
MAILING ADDRESS BROADBENT & ASSOC.
1500 W. CHARLESTON, LAS VEGAS

ADDRESS AT WELL LOCATION TEXACO
1500 W. CHARLESTON
LAS VEGAS, NV.

2. LOCATION SE. ¼ SW ¼ Sec. 33 T. 20 N/S R. 61 E. County

PERMIT NO. MO 2111 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Concrete slab.		0	0.5	0.5
Fill / Silty gravel		0.5	2.0	1.5
Clayey silt		2.0	4.0	2.0
Silty clay		4.0	6.0	2.0
Silty sand w/clay, gravel		6.0	11.0	5.0
Caliche		11.0	14.0	3.0
Silty sand w/clay		14.0	20.0	

RECEIVED
FEB 14 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Dec. 4, 1991
Date completed Dec. 4, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches		0 Feet	20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2.0	SCH. 40	0	20'

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-4' / 2-4' Bent.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout w/ Bent.

Gravel Packed: ☒ Yes ☐ No
From 4' feet to 20' feet

9. WATER LEVEL
Static water level 10.43 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LEBLANC (Contractor)
Address 4670 S. POLARIS (Contractor)
LAS VEGAS, NV.
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589-T1
Signed D. LeBlanc (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627