WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36435
Permit No.
Basin 212

NOTICE OF INTENT NO. 9463

1. OWNER JEXACO
MAILING ADDRESS 1500 W. CHARLESTON
LAS VEGAS, NV (Broadbent & Assoc.)
ADDRESS AT WELL LOCATION JEXACO
1500 W. CHARLESTON
LAS VEGAS, NV.

2. LOCATION SE ¼ SW ¼ Sec. 33 T. 20 N/S R. 61 E County
PERMIT NO. MO 2111 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other Auger.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty Concrete		0	0.5	0.5
Fill / Silty gravel		0.5	1.0	0.5
Silty clay		1.0	6.0	5.0
Sandy silt/w clay		6.0	10.5	4.5
Silty Sand w/gravel		10.5	12.0	1.5
Caliche		12.0	13.0	1.0
Clayey gravel w/sand		13.0	14.0	1.0
Caliche		14.0	15.0	1.0
Sandy clay		15.0	24.5	9.5
Silty Sand w/clay		24.5	35	10.5
Slightly cemented				

RECEIVED
FEB 14 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Dec. 04, 1991
Date completed Dec. 04, 1991

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 35 Feet Depth Cased 35 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10" Inches		0 Feet	35' Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6"	3.45 lbs	SCH 40	0	35'

Perforations:
Type perforation Factory Slotted
Size perforation 0.020
From 5' feet to 35' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 0-4' / 2'-4' Bent.
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout with Bentonite
Gravel Packed: [X] Yes [ ] No
From 4' feet to 35' feet

9. WATER LEVEL
Static water level 9.90 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RICHARD LEBLANC (Contractor)
Address 4670 S. POLARIS (Contractor)
LAS VEGAS NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589-T1
Signed R. LeBlanc (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627