WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36440
Permit No.
Basin 212

NOTICE OF INTENT NO. 3340

1. OWNER Fitzgerald Estate
MAILING ADDRESS Converse Eng Consult 4670 S. Polaris Las Vegas NV
ADDRESS AT WELL LOCATION SE Corner 94th & Stewart

2. LOCATION SE ¼ NE ¼ Sec. 34 T. 20 N/S R. 61 E. Clark County
PERMIT NO. MD-2061 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravelly Silty Sd brown		0	2	2
Clayey Silty Gravel brown		2	4	2
Clay tan		4	8	4
Indurated Clay lt gray		8	14	6
Silt gray		14	15	1
Silty Clay gray		15	25	10

RECEIVED
FEB 14 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started June, 19 91
Date completed June, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 26 Feet Depth Cased 26 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	26 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	PVC	Sched 40	0	26

Perforations:
Type perforation commercial slots
Size perforation 0.02
From 10 feet to 26 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-7.5 5-7.5 bent
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 7.5 feet to 26 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Don Wilson (Contractor)
Address 4670 S. Polaris (Contractor)
Las Vegas NV 89103
Nevada contractor's license number issued by the State Contractor's Board N/A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller H-1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627