WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36449
Permit No.
Basin 212

NOTICE OF INTENT NO. 8284

1. OWNER Engineering Science Inc
MAILING ADDRESS 290 Ellwood Davis Rd.
Liverpool, N.Y. 13088

ADDRESS AT WELL LOCATION Greyhound Bus depot
Main St. Las Vegas

2. LOCATION SW ¼ NW ¼ Sec. 34 T 20 N(S) R 61 E Clark County

PERMIT NO. Mo 2093 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
~~Fill~~:				
Concrete & gravel	Base	0	1	1.0'
Fill: Silty Sand		1	2.5	1.5'
Silty clay & gravel		2.5	10	7.5'
Fine sandy silt				
w/Few stones		10	14.5	4.5
Caliche		14.5	20	5.5
T.D. 20'				

RECEIVED
FEB 21 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Oct. 8, 1991
Date completed Oct. 8, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10" Inches	0 Feet	20' Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2.0	Sch. 40	0	20

Perforations:
Type perforation Factory slotted
Size perforation 0.020
From 5' feet to 20' feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-3.8'/2-3.8' Bent.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout w/Bent.

Gravel Packed: ☒ Yes ☐ No
From 3.8' feet to 20' feet

9. WATER LEVEL
Static water level 10.25 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality ____

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Richard LeBlanc
Address (Contractor) 4670 S. Polaris
Las Vegas, NV. 89103
Nevada contractor's license number issued by the State Contractor's Board ____
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589 T.1
Signed R. LeBlanc (By driller performing actual drilling on site or contractor)
Date 2-14-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627