WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36461
Permit No.
Basin 212

NOTICE OF INTENT NO. 8454

1. OWNER Engineering Science Inc.
MAILING ADDRESS 4906 Gulf Freeway Suite 102 Houston, TX 77034

ADDRESS AT WELL LOCATION Nellis Air Force Base LAS VEGAS NV

2. LOCATION SE ¼ NW ¼ Sec. 3 T. 20 N/S R. 62 E. Clark County

PERMIT NO. MO-2104 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Silty clay		0	17	17
Clay mottled w/calcite		17	22	5
Silty clay w/gravel		22	27	5
Clay, silty		27	47	20
Clay		47	52	5
Silty clay		52	60	8

T.D. = 60'

RECEIVED FEB 28 1992 Div. of Water Resources Branch Office - Las Vegas, NV

Date started 11-21, 1991
Date completed 11-21, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10"	0	60

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	2 lbs	Sch. 40	0	60

Perforations:
Type perforation factory slotted
Size perforation 0.010"
From 30 feet to 60 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-28 / 26-28 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout w/ Bent.
Gravel Packed: ☑ Yes ☐ No
From 28 feet to 60 feet

9. WATER LEVEL
Static water level 53.5 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Richard Le Blanc (Converse Cons.) Contractor
Address 4670 S. Polaris Contractor
Las Vegas, NV
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589T-1
Signed R. LeBlanc
By driller performing actual drilling on site or contractor
Date 2-25-92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627