WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1" Book

OFFICE USE ONLY
Log No. 36516
Permit No.
Basin 212

NOTICE OF INTENT NO. 19879

1. OWNER BAT RENTALS, INC.
MAILING ADDRESS 2771 S. Industrial Rd
Las Vegas, Nevada

ADDRESS AT WELL LOCATION 2771 S. Industrial Rd.
Las Vegas, Nevada

2. LOCATION SE ¼ NW ¼ Sec. 9 T. 21 S/S R. 61 E. Clark County

PERMIT NO. MO-2120 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Lt. brown fine silty sand w/gravel		0	5	5
Cemented tan fine silty sand some gravel	X	5	15	10
Grey Cemented fine silty sand some gravel	X	15	19	4
Grey Cemented fine sandy clay, trace gravel	X	19	20	1

RECEIVED
FEB 25 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 1-22-92, 19
Date completed 1-22-92, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 18 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
7 Inches		0 Feet	20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2	0.69	0.154	0	18

Perforations:
Type perforation Slotted Screen
Size perforation .010
From 8 feet to 18 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 4'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 6 feet to 18 feet

9. WATER LEVEL
Static water level 10.11 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature 68 °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Miller Contractor Law Engineering
Address 4634 S. 36th Place Contractor
Phoenix, AZ 85040
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 179
Signed Wayne Miller / Bob Brand (By driller performing actual drilling on site or contractor) Consultant
Date 2/20/92

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627