WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

In Book

OFFICE USE ONLY
Log No. 36525
Permit No.
Basin 212

NOTICE OF INTENT NO. 9467

1. OWNER G.T. TRUCKING
MAILING ADDRESS C/O WOODWARD CLYDE. 101 Convention Center Dr. LV. NV. 89109

ADDRESS AT WELL LOCATION G.T. TRUCKING HARMON / INDUSTRIAL LAS VEGAS, NV.

2. LOCATION SE ¼ NW ¼ Sec. 20 T. 21 N/S R. 61 E. County

PERMIT NO. MO-2113 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT		0	0.4	0.4
FILL: SILTY gravel		0.4	2.0	1.6
Silt, Sand & gravel		2.0	4.0	2.0
Sand gravel		4.0	10.5	6.5
caliche		10.5	18.0	7.5
SILTY Sand w/clay		18.0	20.0	2.0

RECEIVED
FEB 14 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Dec 6, 19 91
Date completed Dec. 6, 19 91

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches	0 Feet	20 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2"	.7 lbs	SCH. 40	0	20

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 0.020
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-4 / 2-4 Bent.
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout w/Bent.
Gravel Packed: ☑ Yes ☐ No
From 4 feet to 20 feet

9. WATER LEVEL
Static water level 10.74 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON (Contractor)
Address 4670 So. POLARIS (Contractor)
LAS VEGAS, NV. 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M 1589
Signed (By driller performing actual drilling on site or contractor)
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627