



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9197

1. OWNER Mary Klapp ADDRESS AT WELL LOCATION 2545 BENO.  
 MAILING ADDRESS 2545 E BENO AVE Las Vegas NV  
 2. LOCATION S.W. 1/4 NW 1/4 Sec. 25 T. 21S N/S R. 61 E. Clark County  
 PERMIT NO. 150-830-013-91. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Municipal/Industrial  Irrigation  Monitor  Test  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Clay		0	5	5
Hard. Caliche		5	8	3
Clay & Gravel		8	38	30
Caliche	WB	38	42	4
Clay		42	70	28
Caliche	WB	70	78	8
Clay		78	100	22
Caliche	WB	100	108	8
Clay		108	135	27
Caliche	WB	135	145	10
Clay		145	170	25
Caliche	WB	170	180	10
Clay		180	210	30
Cement & Gravel		210	215	5
SAND & GRAVEL	WB	215	300	85

8. WELL CONSTRUCTION  
 Depth Drilled 300 Feet Depth Cased 300 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 300 Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>1.88</u>	<u>- 2</u>	<u>300</u>

Perforations:  
 Type perforation SAW  
 Size perforation 1/8 inch by 3 inch  
 From 220 feet to 300 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 210 FT.  Neat Cement  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 210 feet to 300 feet

9. WATER LEVEL  
 Static water level 32 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

RECEIVED  
 JAN 07 1992

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 4-15, 1991  
 Date completed 4-20, 1991

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCB 78 Box 80358 Contractor  
Pahrump NV. 89641  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426  
 Signed Steve Plume  
 By driller performing actual drilling on site or contractor  
 Date 6-30-91