WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

in Book

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36531
Permit No.
Basin 212

NOTICE OF INTENT NO. 9482

1. OWNER TEXACO REFINING & MARKETING, INC.
MAILING ADDRESS 10 UNIVERSAL CITY PLAZA
UNIVERSAL CITY, CA 91608

ADDRESS AT WELL LOCATION
4910 S. MARYLAND PARKWAY
LAS VEGAS, NV 89119

2. LOCATION NW ¼ NW ¼ Sec. 26 T. 21 N/S R. 61 E. CLARK County

PERMIT NO. MO-2119 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SILTY SAND		0	3	3
GRAVELLY SAND		3	8	5
CALICHE		8	12.5	4.5
SILTY SAND		12.5	13.5	1
CALICHE		13.5	15	1.5
SILTY SAND		15	16	1
SANDY CLAY		16	19	3
SILTY CLAY		19	20	1

RECEIVED
FEB 11 1992
Div. of Water Resources
Branch Office Las Vegas, NV

Date started JAN. 23, 19 92
Date completed JAN 23, 19 92

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 20 Feet Depth Cased 20 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
6 Inches		0 Feet	20 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		SCH 40 - PVC	0	20

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 0.020"
From 5 feet to 20 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 3
Placement Method: ☐ Pumped ☒ Poured

Seal Type:
☒ Neat Cement
☐ Cement Grout
☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 20 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Contractor
Address 4670 S. POLARIS AV.
Contractor
LAS VEGAS, NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-1589
Signed
By driller performing actual drilling on site or contractor
Date

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627