WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 36544
Permit No.
Basin

Book

NOTICE OF INTENT NO. 3927

1. OWNER Donald Owens
MAILING ADDRESS Same
ADDRESS AT WELL LOCATION 8755 Westwind Las Vegas, NV

2. LOCATION SE ¼ SW ¼ Sec 13 T 22 S N/S R 60 E Clark County
PERMIT NO. Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	8	
Cemented Gravel		8	12	
Gravel		12	28	
Cemented Gravel		28	36	
Clay Gravel		36	180	
Boulders		180	230	
Clay Gravel		230	260	
Boulders		260	280	
Clay Gravel		280	410	
Gravel & Water		410	420	
Clay Gravel		420	460	
Gravel & Water		460	500	

RECEIVED
JAN 07 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 12-24-91, 19
Date completed 12-31-91, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 500 Feet Depth Cased 500 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches	0 Feet	55 Feet	
9 7/8" Inches	55 Feet	500 Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	500

Perforations:
Type perforation Factory
Size perforation 3/16" x 8 row
From 460 feet to 480 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 55
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☒ No
From feet to feet

9. WATER LEVEL
Static water level 335 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Vernon H. Dimick Contractor
Address 7115 Rogers St. Contractor
Las Vegas, Nev. 89118
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed Vernon H. Dimick By driller performing actual drilling on site or contractor
Date January 2, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627