

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 9187

1. OWNER CITY OF HENDERSON ADDRESS AT WELL LOCATION Bomb Shelter Site  
Yucca Rd + Lake Mead Blvd  
Henderson NV  
 MAILING ADDRESS 240 WATER STREET  
Henderson NV 89015  
 2. LOCATION 1/4 Sec. 87 T. 22 N. R. 63 E. CLARK County  
 PERMIT NO. SE 110-22-66 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other Temp.  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Silty Sand</u>		<u>0'</u>	<u>2'</u>	<u>2'</u>
<u>sandy silt</u>		<u>2'</u>	<u>21'</u>	<u>19'</u>
<u>SANDY GRAVEL</u>		<u>21'</u>	<u>30'</u>	<u>9'</u>
<u>Gravelly sand</u>		<u>30'</u>	<u>40'</u>	<u>10'</u>
<u>SANDY GRAVEL</u>		<u>40'</u>	<u>56'</u>	<u>16'</u>
<u>CLAY w/ silt</u>		<u>56'</u>	<u>70'</u>	<u>14'</u>
<u>Clayey silt</u>		<u>70'</u>	<u>74'</u>	<u>4'</u>
<u>CLAY</u>		<u>74'</u>	<u>87'</u>	<u>13'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 87 Feet Depth Cased 85 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 Inches To \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:  
 Type perforation Factory Slotted  
 Size perforation 0.020  
 From 85 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 85 feet to 50 feet

RECEIVED

FEB 11 1992

Div. of Water Resources  
 Branch Office Las Vegas, NV

Date started 4-22 1992  
 Date completed 4-27 1991

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	

9. WATER LEVEL  
 Static water level ~54 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_  
 10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Don Wilson Contractor  
 Address 4670 S. Polaris Ave Contractor  
LAS VEGAS NV. 89103  
 Nevada contractor's license number issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589  
 Signed Don Wilson  
 By driller performing actual drilling on site or contractor  
 Date \_\_\_\_\_