

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 8080

1. OWNER John Ellenburg ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS _____
 2. LOCATION SW 1/4 NW 1/4 Sec. 22 T. 24S N/S R. 56 E Clark County _____
 PERMIT NO. 580-160-113 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Loam		0	15	15
Caliche		15	18	3
Clay		18	42	24
Caliche		42	47	5
Clay & Gravel		47	60	13
Caliche		60	72	12
Cemented Sand & Gravel		72	98	26
Clay		98	112	14
Caliche	WB	112	120	8
Clay		120	148	28
Caliche	WB	148	150	2
Clay		150	162	12
Caliche	WB	162	168	6
Clay		168	180	12

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet
 HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches To 0 Feet 50 Feet
9 7/8 Inches 50 Feet 180 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>	<u>16.94</u>	<u>1.88</u>	<u>0</u>	<u>180</u>

Perforations:
 Type perforation Factory Sawcut
 Size perforation 1/2 x 3/8
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From _____ feet to _____ feet

RECEIVED

FEB 27 1992

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 2-10 1992
 Date completed 2-17 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 120 ft feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Co Contractor
 Address HCR 78 Box 80358 Contractor
Pahrump NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 30880
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dun
 By driller performing actual drilling on site or contractor
 Date 2-22-92