WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36577
Permit No.
Basin 163

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 6151

1. OWNER Carl Chaves
MAILING ADDRESS Box 335 HCR 31
Sandy Valley Nv. 89019

ADDRESS AT WELL LOCATION South & Marble Ave
Sandy Valley

2. LOCATION SW ¼ SE ¼ Sec. 26 T. 24 N/S R. 56 E CLARK County
PERMIT NO. (Issued by Water Resources) Parcel No. 580-240-047-92 Subdivision Name

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☒ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CALICHE		0	15	15
WHT CLAY		15	20	5
CONS CLAY		20	25	5
GREEN CLAY		25	28	3
WHT CLAY		28	37	9
BRN CLAY		37	53	16
WHT CLAY		53	59	6
CALICHE	WTR	59	61	2
BRN CLAY		61	74	13
CORAL		74	77	3
WHT CLAY		77	79	2
CORAL		79	81	2
WHT CLAY		81	94	13
CALICHE	WTR	94	96	2
BRN CLAY		96	109	13
WHT CLAY		109	119	10
CALICHE	WTR	119	120	1
WHT CLAY		120	128	8
CALICHE	WTR	128	130	2

RECEIVED
FEB 10 1992
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started JAN 30, 1992
Date completed FEB 8, 1992

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. 3.75 Draw down 3 feet 2 hours
G.P.M. Draw down feet hours
G.P.M. Draw down feet hours

8. WELL CONSTRUCTION
Diameter 14 inches Total depth 130 feet
inches
inches
Casing record 8" STEEL
Weight per foot 18 Thickness 1188

Diameter	From	To
8 inches	0 feet	130 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type CEMENT
Depth of seal 50 feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 130 feet

Perforations:
Type perforation FLAME CUT
Size perforation 3/8 X 4" 4 ROWS @ 16" CTRS
From 110 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

9. WATER LEVEL
Static water level 53 feet below land surface
Flow G.P.M. P.S.I.
Water temperature 64 °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name RCBB INC. Contractor
Address 1701 W. Charleston, Las Vegas Nv. 89102 Contractor
Nevada contractor's license number issued by the State Contractor's Board 020301
Nevada contractor's driller's number issued by the Division of Water Resources 1352
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1352
Signed Robert Spurlock By driller performing actual drilling on site or contractor
Date Feb 8 92

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627