WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

in Book

OFFICE USE ONLY
Log No. 36578
Permit No.
Basin 163

NOTICE OF INTENT NO. 8058

1. OWNER Grover Craft
MAILING ADDRESS
ADDRESS AT WELL LOCATION (Sandy Valley)

2. LOCATION NE ¼ NE ¼ Sec. 36 T. 24S N/S R. 56 E. Clark County
PERMIT NO. N/A (Issued by Water Resources) Parcel No. Lot 4 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy loam		0'	7'	7'
Clay		7'	12'	5'
Caliche		12'	14'	2'
Clay		14'	19'	5'
Caliche		19'	23'	4'
Clay		23'	26'	3'
Caliche		26'	29'	3'
Clay		29'	57'	28'
Caliche	WB	57'	61'	4'
Clay		61'	68'	7'
Caliche	WB	68'	71'	3'
Clay		71'	86'	15'
Caliche	WB	86'	93'	7'
Clay		93'	112'	19'
Caliche	WB	112'	115'	3'
Clay		115'	122'	7'
Caliche	WB	122'	126'	4'
Clay		126'	130'	4'

RECEIVED
NOV 27 1991
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 10-23, 1991
Date completed 10-28, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 130' Feet Depth Cased 130' Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0' Feet	50' Feet
9 7/8 Inches		50' Feet	130' Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0'	130'

Perforations:
Type perforation sawcut
Size perforation 1/8 x 3
From 130' feet to 110' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 130' feet to 50' feet

9. WATER LEVEL
Static water level 44' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cool °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 80358 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1573
Signed (By driller performing actual drilling on site or contractor)
Date 11-25-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627