WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 36591
Permit No.
Basin 84

PRINT OR TYPE ONLY 30ADB

NOTICE OF INTENT NO. 17573

1. OWNER: RON & LINDA BURKLIN
MAILING ADDRESS: 413 E. Wilson, Rialto, CA 92376
ADDRESS AT WELL LOCATION: 4580 Cactus Canyon Road, Reno, NV 89510

2. LOCATION: SE ¼ NE ¼ Sec. 30 T. 22N N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-150-12 (Parcel No.) Beacon Rind Flats, Palomino Valley Unit 4 (Subdivision Name) 29-2-1-1 part 4

3. TYPE OF WORK: New Well [X] Recondition [ ] Deepen [ ] Other [ ]

4. PROPOSED USE: Domestic [X] Irrigation [ ] Test [ ] Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL: Cable [ ] Rotary [X] Other [ ] Air

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Fill		0	5	5
Decomposed granite		5	12	7
Hard weathered granite		12	170	158
Very hard gray granite		170	251	81
Soft zone, rusty colord		251	262	11
Very hard gray granite with small soft zone		262	397	35
Very hard weathred granite		297	434	37
Fractured (NO WATER)		434	438	4
Very hard gray granite		438	490	52
Fractured (NO WATER)		490	491	1
Very hard weathered granite		491	530	39
Fractured (NO WATER)		530	533	3
Very hard weathered granite		533	540	7
FRactured (NO WATER)		540	542	2
Very hard weathered granite		542	549	7
Hard weathered granite		549	559	10
Fractured (NO WATER)		559	560	1
Very hard gray granite		560	618	58
Soft zone,gray clay		618	655	37
Very hard gray granite		655	680	25
Very hard gray granite with small water bearing fractures	X	680	725	45

Water bearing fractures @ 682,685,689,673,704, 710, 712, 714, 715, 719, 724.

Date started 5-17-91, 19
Date completed 5-24-91, 19

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours
G.P.M. ____ Draw down ____ feet ____ hours

8. WELL CONSTRUCTION
Diameter 8 5/8 inches, 10 inches, inches — Total depth 725 feet, 0 to 50ft
Casing record 725' steel casing installed.
Weight per foot ____ Thickness .188

Diameter	From	To
6 5/8 inches	0 feet	725 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes [X] No [ ] Type cement grout
Depth of seal 50 feet
Gravel packed: Yes [X] No [ ]
Gravel packed from 50 feet to 725 feet

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 660 feet to 720 feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 580 feet below land surface
Flow 18 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name (Contractor) Wayne Drilling, Inc.
Address (Contractor) P.O. Box 12370, Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada contractor's driller's number issued by the Division of Water Resources 908
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1754
Signed (By driller performing actual drilling on site or contractor)
Date May 31, 1991

JUN -4 AM 9:37 '91

(Rev. 11-85) USE ADDITIONAL SHEETS IF NECESSARY (O)-627