

OFFICE USE ONLY
 Log No. 36617
 Permit No. _____
 Basin. 4-52

WELL DRILLER'S REPORT

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 13593

1. OWNER Newmont Gold Company ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P.O. Box 669
Carlin, NV 89822 CS-2
 2. LOCATION NE 1/4 SE 1/4 Sec. 21 T 33 N35 R. 51 E. Eureka County
 PERMIT NO. M/0-184-D Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. Monitor
 Domestic Municipal

PROPOSED USE
 Irrigation Industrial Test Stock

5. TYPE WELL
 Cable Rotary Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|-----------------------|--------------|------|-----|------------|
| Tan clay & gravel | | 0 | 195 | 195 |
| Gray siltstone | | 195 | 210 | 15 |
| Tan clay & gravel | | 210 | 220 | 10 |
| Broken blk. siltstone | | 220 | 380 | 160 |
| Siltstone | x | 380 | 625 | 245 |
| Controlled by a valve | | | | |
| Cement seal | | 420 | 380 | 40 |

8. WELL CONSTRUCTION

Diameter _____ inches Total depth 625 feet
9-1/2 inches 0 - 420
6 inches 420 - 625

Casing record Steel
 Weight per foot 17# Thickness .250

| Diameter | From | To |
|-----------------|----------------|-----------------|
| <u>6</u> inches | <u>+1</u> feet | <u>419</u> feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |
| _____ inches | _____ feet | _____ feet |

Surface seal: Yes No Type Cement
 Depth of seal 100 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started 6-17, 1991
 Date completed 6-26-91, 1991

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
| | | | |
| | | | |
| | | | |

9. WATER LEVEL

Static water level Flowing feet below land surface
 Flow 600 G.P.M. 18 P.S.I.
 Water temperature 68 °F Quality Good

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Elsing Drilling & Pump Co., Inc.
 Address P.O. Box 919 Twin Falls, ID 83303
 Nevada contractor's license number issued by the State Contractor's Board 0017177
 Nevada contractor's driller's number issued by the Division of Water Resources 1295
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 945
 Signed Arnold Elsing
 Date July 27, 1991

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours