WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 36638
Permit No.
Basin 49

NOTICE OF INTENT NO. 16892

1. OWNER GERRIT BOWDEN
MAILING ADDRESS 160-2 Kittridge Canyon Elko, NV 89801

ADDRESS AT WELL LOCATION NORTH SIDE OF WEST 8th BETWEEN SEMINOLE & PIMA
Lots Block 52

2. LOCATION NW ¼ SW ¼ Sec. 35 T. 35 N/S R. 55 E Elko County
PERMIT NO. (Issued by Water Resources) 37-052-06-5 (Parcel No.) Meadow Valley Ranchos Unit #5 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 3 | 3 |
| Clay | | 3 | 20 | 17 |
| Siltstone conglomerate | 120 | 20 | 200 | 180 |
| Siltstone clay (brown, pink, green | 240 | 200 | 300 | 100 |

RECEIVED JUN 14 '91 10:52 STATE ENGINEER'S OFFICE

Date started June 6, 1991
Date completed June 10, 1991

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | | |

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 10 5/8 Inches | 0 Feet | 300 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | 13 | .188 | +2 | 300 |

Perforations:
Type perforation Mill slot
Size perforation 1/8 x 2½
From 258 feet to 300 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100
Placement Method: ☒ Pumped ☒ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 300 feet

9. WATER LEVEL
Static water level 60 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature C °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name HACKWORTH DRILLING, INC. (Contractor)
Address P.O. Box 850 Elko, NV 89801 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 020582
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1689
Signed Daniel Hersh (By driller performing actual drilling on site or contractor)
Date 6-12-1991

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627